

MINUTEMAN[®]

Power Technologies

From Para Systems, Inc.

EDBP6000RM Quick Install

Please read all of the WARNINGS, CAUTIONS and the UPS User's Manual before attempting to install Battery Pack module (EDBP6000RM).

WARNING: This UPS system contains potentially hazardous voltages. Risk of Electrical shock. The internal batteries energize hazardous live parts inside this UPS even when the AC input power is disconnected.

NOTE: Installing or Servicing of the UPS system must be performed by **Qualified Service Personnel ONLY**. MINUTEMAN accepts no liabilities and is not limited to: injury to the Service Personnel, or damages to; the UPS system, or the connected equipment caused by the incorrect installation or servicing of the UPS system.

WARNING: **DO NOT ATTEMPT TO INSTALL THE BATTERY PACK MODULE WITH THE UPS SYSTEM TURNED ON.** The UPS MUST be in the Off position. The Utility power's circuit breaker MUST be in the Off position. The Battery Pack module's DC circuit breaker MUST be in the Off position.

1. See the UPS User's Manual for wiring and installing the Battery Pack module (EDBP6000RM).

